


- ① CAST IRON FLUSHING INLET, FRAME AND COVER, D & L SUPPLY H-6530 OR APPROVED EQUAL W/C.O.
- ② ONE HALF (1/2) INCH BY ONE (1) INCH PICK HOLE.
- ③ FIVE EIGHTHS (5/8) INCH BY ONE AND ONE HALF (1 1/2) INCH LONG, COURSE THREADED, BRASS HEX HEAD BOLTS TO BE INSTALLED WHEN RISER IS PLACED OUTSIDE PAVED AREA.
- ④ CRUSHED BEDDING; SEE DIVISION IV, SECTION 12.
- ⑤ PROPOSED SEWER MAIN.
- ⑥ UNDISTURBED SOIL.
- ⑦ AGGREGATE BASE; SEE DIVISION IV, SECTION 12.
- ⑧ CLASS "A" CONCRETE WITH 2" A.C.
- ⑨ ONE EIGHTH (1/8) BEND.
- ⑩ SIX (6) INCH BY EIGHT (8) INCH INCREASER (IF REQUIRED).
- ⑪ RUBBER END CAP WITH STAINLESS STEEL SHEAR BAND.

THE CITY OF WEST SACRAMENTO – STANDARD DETAIL

APPROVED BY: 	C- 38733	3/31/05
CITY ENGINEER	P.E. NO.	DATE
REVISION:		
REVISION:		
REVISION:		
REVISION:		

TITLE: SEWER FLUSHING INLET

STANDARD DETAIL #: 402

